



CONSTRUCTION NOTES:

- > All zoned distances are measured from the wire regardless of construction type to minimize tree-conductor interference under adverse weather conditions and a 5-year maintenance cycle.
- > Diameter at breast height (dbh) measured 4-1/2' above ground.
- > Previously topped trees within the clearing zones are not considered structurally sound.

EFSEC/Sumas
03/04/00

Source: Dames & Moore

Figure 3.4-5b
Vegetation Management Requirements For Overhead Transmission Lines, Part 2